



Note: The delivery figures below are for firm contracted thermal fuel (Gas and Coal) available to Genesis Energy for use at Huntly units 1 to 6, and Te Awamutu, in the months shown. Genesis Energy may vary the actual uptake of either, gas, or coal, or both, to manage business requirements going forward.

Forecast Fuel delivery figures for general publication

	Apr-07	May-07	Jun-07	Jul-07	Aug-07	Sep-07	Oct-07	Nov-07	Dec-07	Jan-08	Feb-08	Mar-08	Apr-08
1 Coal Stockpile at 22/04/07 (PJ's)	19.0												
2 Oil Stockpile at 31/03/07 (PJ's)	0.03												
3 Forecast Monthly deliveries in Petajoules (PJ's) per month.	7.28	6.97	6.73	7.71	7.70	7.61	7.47	7.44	6.22	5.76	5.63	5.81	6.46

Disclaimer:

This information has been compiled by Genesis Energy Limited ("Genesis") for information purposes only. While Genesis has used all reasonable endeavours to ensure the factual accuracy of the information provided, errors, inaccuracies and omissions may occur. Genesis does not guarantee the accuracy or completeness of the fuel figures and does not accept any liability or responsibility for any error, inaccuracy, or omission or for the use of such information by the Ministry of Economic Development, the Electricity Commission or any other person. Any person using these figures accepts all risk and responsibility for any loss, damage, cost or other consequence resulting directly or indirectly from the use of the figures.

All deliveries are subject to the normal ability of producers to deliver and are subject to delivery risks including but not limited to: mine failures, resource consents, RMA issues, failure of the supplier to perform staffing issues, transportation ability, shipping and stevedoring risks, strikes, insurgency and political unrest, legislative, any future Maui re-determinations, governmental or other prohibitions or restrictions, force majeure events or other causes whatever beyond Genesis' reasonable control. Note that a proportion of the above indicated deliveries are also subject to spot availability

Genesis publishes its plant outages along with other industry participants on the web site:

<http://pocp.redspider.co.nz>

In addition, generation at Huntly Energy station can be restricted by resource consent conditions to as little as 80MW total generation. These restrictions are related to the temperature of the Waikato river which is used to cool the station.

Typically this restriction occurs in the period December to April. The extent of the restriction is dictated by climatic conditions at the time.