



Grid Emergency Report

To: GEN NZ Participants

From: The System Operator

Sent:

Telephone: 0800 488 500

Ref: 84881249

Facsimile: 07 843 7176

Revision of:

Grid Emergency Notice ref: 84781919

Cause:	Insufficient Generation offers North Island
At:	North Island
Starting:	14-oct-2009 17:49
Ending:	14-oct-2009 22:00
Action Taken:	North Island CE RAF's were zeroed from 17:49 until 19:45.

Rule GIII 8.1 of the Electricity Governance Rules and Regulations and Part C schedule C4 Policy Statement para 62.

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.