

To: Electricity Governance Board

From: Transpower as System Operator

---

A Grid Emergency was declared on 20th July 2009 at 08:34 hours until 09:49 hours, pursuant to rule GIII 8.1 of the Electricity Governance Rules and Regulations.

In accordance with Part C schedule C4 Policy Statement, a Grid Emergency was declared at Mangamaire. A loss of Bunnythorpe-Linton 1 or Haywards-Linton 1 would overload Mangamaire Woodville 1 circuit.

Grid was reconfigured placing a system split at Mangamaire by opening circuit breaker 172 on the Mangamaire Masterton 1 circuit.