

## ELECTRICITY GOVERNANCE RULES 2003

### 2008 GRID UPGRADE PLAN

#### Resubmission of Bombay Bus Security Investment Proposal

On 30 June 2009, Transpower New Zealand Limited (**Transpower**) resubmitted to the Electricity Commission the Bombay Bus Security Investment Proposal under rule 13 of section III of part F of the Electricity Governance Rules 2003.

The resubmission of the Bombay Bus Security Investment Proposal is a reliability investment, and involves the installation of a bus coupler circuit breaker, full local backup protection and bus zone protection measures for the 110kV busbar at Bombay substation.

The Electricity Commission has published the proposal on its website:

<http://www.electricitycommission.govt.nz/opdev/transmis/gup/2008GUP/bombay#resubmission>

Under rules 13.3.2 and 13.3.5 of section III of part F of the Electricity Governance Rules 2003, the Electricity Commission gives notice that it is providing designated transmission customers and affected parties with an opportunity to:

- a) Provide written comments on the proposals; and
- b) Request that the Commission consider alternatives to the proposal

Comments and/or requests must be received by the Electricity Commission by **5.00pm** on **Thursday, 23 July 2009**.

**Please note that comments and/or requests received after this deadline are unlikely to be considered.**

Further details of how designated transmission customers and affected parties can provide their input, can be found at:

<http://www.electricitycommission.govt.nz/consultation/bombayresubmission>

Dated at Wellington this 2<sup>nd</sup> day of July 2009.



**MERVYN ENGLISH**  
**General Manager**  
**Electricity Commission**